



For SI units, 1 ft = 0.3048 m

Note 1: 5 ft minimum front relief valve in any direction away from any exterior source of ignition, openings into direct-vent appliances, or mechanical ventilation air intakes. Refer to 6.3.7(2).

Note 2: If the cylinder is filled on site from a bulk truck, the filling connection and vent valve must be at least 10 ft from any exterior source of ignition, openings into direct-vent appliances, or mechanical ventilation air intakes. Refer to 6.3.10.

Note 3: Refer to 6.3.7(1).

FIGURE I.1(a) Cylinders. (This figure for illustrative purposes only; code shall govern.)